

Carson Valley Middle School

Testing Period: January 2013

Room	Start Date	End Date	Result (pCi/L)
3	1-7-13	1-9-13	2.5
20	1-7-13	1-9-13	3.2
24	1-7-13	1-9-13	<0.3
24	1-7-13	1-9-13	5.7
24	1-7-13	1-9-13	6.3

For results above 4.0 (red text), adjustments are being made to the HVAC systems, and the rooms will be tested in closed-conditions again to confirm that the adjustments lowered the levels being reported. Updated results will be posted once those areas have been retested.