

George Whittell High School

Testing Period: January 2013

Room	Start Date	End Date	Result (pCi/L)
Copy Room	1-7-13	1-9-13	<0.3
Copy Room	1-7-13	1-9-13	3.5
Coaches Office	1-7-13	1-9-13	7.3
Kiln Room	1-7-13	1-9-13	<0.3
Kiln Room	1-7-13	1-9-13	0.8

For results above 4.0 (red text), adjustments are being made to the HVAC systems, and the rooms will be tested in closed-conditions again to confirm that the adjustments lowered the levels being reported. Updated results will be posted once those areas have been retested.