

CVMS Radon Test Results
Testing Period: January 2014

Room	Start Date	End Date	Result (pCi/L)
Room 3	1/13/14	1/15/14	4.2
Room 20	1/13/14	1/15/14	2.3
Room 24	1/13/14	1/15/14	No Result
Room 24	1/13/14	1/15/14	5.8

****Room 24 continues to show elevated results in the tests performed. This room has been repurposed and is now used only as a storage room, not to be used as classroom or office. Further retesting is unnecessary.**