

**GES Radon Test Results**  
**Testing Period: January 2014**

Room	Start Date	End Date	Result (pCi/L)
Room 210	1/13/14	1/15/14	1.7
Room 212	1/13/14	1/15/14	1.4
Room 217	1/13/14	1/15/14	2.2
Room 218	1/13/14	1/15/14	5.7
Room 219	1/13/14	1/15/14	2.5
Room 220	1/13/14	1/15/14	2.8
Room 223	1/13/14	1/15/14	1.7
Room 300	1/13/14	1/15/14	3.8
Room 301	1/13/14	1/15/14	2.8
Room 302	1/13/14	1/15/14	3.3

\*\*Room 218 returned a level higher than 4.0 pCi/L during the January closed-conditions testing. HVAC adjustments were made to the system, and it was retested immediately thereafter. That testing returned the result below, well below 4.0 pCi/L. There is no need for any additional mitigation efforts at this time, and the room will be tested during the annual 2014-2015 winter closed-conditions testing per District protocol.

Room	Start Date	End Date	Result (pCi/L)
Room 218	1/27/14	1/29/14	2.5