

ZCES Radon Test Results
Testing Period: January 2014

Room	Start Date	End Date	Result (pCi/L)
MPR	1/13/14	1/15/14	4.8
Library	1/13/14	1/15/14	1.8
Room 1	1/13/14	1/15/14	1.4
Room 6	1/13/14	1/15/14	1.2
Room 12	1/13/14	1/15/14	2.4
Room 19	1/13/14	1/15/14	1.3

****The MPR returned a level higher than 4.0 pCi/L during the January closed-conditions testing. HVAC adjustments were made to the system, and it was retested immediately thereafter. That testing returned the result below, well below 4.0 pCi/L. There is no need for any additional mitigation efforts at this time, and the room will be tested during the annual 2014-2015 winter closed-conditions testing per District protocol.

Room	Start Date	End Date	Result (pCi/L)
MPR	1/27/14	1/29/14	2.5