

GES Radon Test Results
Testing Period: February 2015

Room	Start Date	End Date	Result (pCi/L)
Room 218	2/2/15	2/4/15	1.5

Results are below 4.0 pCi/L; no further action required.