

PWLMS Radon Test Results
Testing Period: February 2015

Room	Start Date	End Date	Result (pCi/L)
Room G-8	2/2/15	2/4/15	3.1

Results are below 4.0 pCi/L; no further action required.