

Heritage Building Radon Test Results
Testing Period: February 2015

Room	Start Date	End Date	Result (pCi/L)
Room 1	2/2/15	2/4/15	2.7
Room 2	2/2/15	2/4/15	1.4
Room 3	2/2/15	2/4/15	2.2
Room 4	2/2/15	2/4/15	1.9
Room 5	2/2/15	2/4/15	1.7
Room 6	2/2/15	2/4/15	2.1
Room 7	2/2/15	2/4/15	2.7
Room 8	2/2/15	2/4/15	2.6
Room 9	2/2/15	2/4/15	2.8
Room 10	2/2/15	2/4/15	3.4
Room 10	2/2/15	2/4/15	<0.3
Room 11	2/2/15	2/4/15	3.6
Room 12	2/2/15	2/4/15	2.5
Room 13	2/2/15	2/4/15	1.1
Room 14	2/2/15	2/4/15	0.5

Results are below 4.0 pCi/L; no further action required.